

Company Directive

ENGINEERING SPECIFICATION EE SPEC : 74/3

Specification for Low Voltage Service and Mains Type Cables

Author: Richard Summers

Implementation Date: April 2020

Approved by



Carl Ketley-Lowe
Engineering Policy Manager

Date: 2nd April 2020

Target Staff Group	N/A
Impact of Change	Green – No major impact
Planned Assurance checks	N/A

All references to Western Power Distribution or WPD must be read as National Grid Electricity Distribution or NGED

NOTE: The current version of this document is stored in the NGED Corporate Information Database. Any other copy in electronic or printed format may be out of date. Copyright © 2022 National Grid Electricity Distribution

IMPLEMENTATION PLAN

Introduction

This document defines the low voltage (LV) service and mains cables used within WPD and provides a standard with which the Purchasing section can tender with.

Main Changes

The tolerance for the tensile strength of solid aluminium conductor has been reduced to ensure conductors are easy to bend when jointing.

A requirement to print/emboss waveform cable sheaths with “Property of WPD” added.

Impact of Changes

No major impact.

Implementation Actions

N/A

Implementation Timetable

Immediate.

REVISION HISTORY

Document Revision & Review Table		
Date	Comments	Author
April 2020	• Tensile strengths added to section 4 • “Property of WPD” added for waveform cable	Richard Summers
January 2015	• Removal of 4mm and 16mm Cu cables	Richard Summers
October 2013	• Update of BS numbers, consolidation into one specification and update of schedule 1	Richard Summers

Contents

1.0	SCOPE	5
2.0	SPECIFICATION FOR SERVICE CABLES	5
3.0	SPECIFICATION FOR WAVEFORM MAINS CABLES	5
4.0	VARIATIONS	6
5.0	SIZES AND DRUM LENGTHS	6
6.0	DELIVERY	6
	APPENDIX 1	7
	APPENDIX A	9
	APPENDIX B	9
	APPENDIX C	9

1.0 SCOPE

This Specification gives the requirements for the supply and delivery of service and mains cables for use on the Western Power Distribution 230/400 Volt (WPD's) distribution systems. Low Voltage single core Solidal cables are covered in WPD Specification EE75.

2.0 SPECIFICATION FOR SERVICE CABLES

XLPE insulated combined neutral and earth (copper wire) concentric cables with copper and aluminium conductors to BS 7870-3.11:2011. The 35mm² copper conductor version of the CNE cable is to be generally manufactured to this British Standard. For variation see section 4

XLPE insulated split concentric cables with copper and aluminium conductors to BS 7870-3.21:2011. For variation see section 4

XLPE insulated split concentric cables with copper and aluminium conductors having low emission of smoke and corrosive gases (LSF) when affected by fire to BS 7870-3.22:2011. For variation see section 4

XLPE insulated split concentric cables with copper and aluminium conductors having low emission of smoke and corrosive gases (LSF) when affected by fire to BS 7870-3.12:2011. For variation see section 4.

3.0 SPECIFICATION FOR WAVEFORM MAINS CABLES

Standard three and four core Waveform cables shall be manufactured in accordance with BS 7870-3.40:2011 XLPE insulated, copper wire waveform concentric cables with solid aluminium conductors. For variation see section 4

LSF variations shall be manufactured in accordance with BS 7870-3.50:2011 XLPE insulated, copper wire Waveform or helical concentric cables with solid aluminium conductors, having low emission of smoke and corrosive gases when affected by fire.

For variation see section 4.

4.0 VARIATIONS

Cable Over-sheaths

Over-sheaths for all non LSF cables will be black and shall be installed by the “float down” method thereby preventing the oversheath from penetrating the separate neutral earth wires. For LSF cable the cable sheath shall be orange.

Security

Service cables are to be uniquely traceable to WPD, this can be achieved by embossing of the cable oversheath / conductor or other methods approved by WPD.

Waveform cables shall also be marked externally with the words “PROPERTY OF WPD”. This marking can be either printed or embossed.

Insulation Shrinkage

A sample of core is tested at $(60 \pm 2)^\circ\text{C}$ for 4 h in accordance with BS EN 60811-1-3, Clause 10, the shrinkage of the insulation from all types and sizes of cable shall not exceed 2%.

Tensile Strength of Solid Aluminium Conductors

Nominal cross-sectional area mm^2	Tensile strength N/mm^2
25 and 35	60 to 105
70 and above	60 to 70

5.0 SIZES AND DRUM LENGTHS

The standard size drum lengths shall be a maximum of 250m unless agreed with WPD

6.0 DELIVERY

WPD have two modes of supply for mains cables: - Cable supplied to stores is required in drum lengths. Just in Time (JIT) cables can be ordered in any length greater than 50m, these lengths will be required to be delivered to our local depots or directly to site. Details of the JIT system are contained elsewhere in the tender documentation.

APPENDIX 1

SPECIFICATION FOR LOW VOLTAGE THREE PHASE MAINS CABLES.

ITEM NO.	SHOPS CODE	DESCRIPTION
	41347	1 Core 25mm ² Cu CNE – 250m
	41361	1 Core 25mm ² Cu CNE – 100m
	41349	1 Core 35mm ² Cu CNE – 250m
	41355	1 Core 25mm ² SAC CNE Service Cable – 250m
	41362	1 Core 25mm ² SAC CNE Service Cable – 100m
	41348	1 Core 35mm ² SAC CNE Service Cable – 250m
	41363	1 Core 35mm ² SAC CNE Service Cable – 100m
	41353	1 Core 25mm ² Cu SNE – 250m
	50000	1 Core 35mm ² SAC SNE – 250mm
	41966	1 Core 25mm ² SNE LSF – 250m
	50004	1 Core 35mm ² SAC CNE Service Cable LSF – 250m
	41351	3 Core 25mm ² Cu CNE Service Cable – 250m
	41356	3 Core 25mm ² SAC CNE Service Cable – 250m
	41357	3 Core 35mm ² SAC CNE Service Cable – 250m
	41354	3 Core 25mm ² Cu SNE – 250m
	50003	3 Core 35mm ² SAC SNE – 250m
	42144	3 Core 25mm ² Cu SNE LSF – 250m
	52949	3 Core 35mm ² Hybrid CNE LSF – 250m
	41345	3 core 95mm ² Waveform mains cable – 250m

	41344	3 core 185mm ² Waveform mains cable – 250m
	41343	3 core 300mm ² Waveform mains cable – 250m
	41342	4 core 95mm ² Waveform mains cable – 250m
	41341	4 core 185mm ² Waveform mains cable – 250m
	41340	4 core 300mm ² waveform mains cable – 250m
	41336	4 core 300mm ² Cu waveform mains cable – 250m
	41883	3 core 95mm ² LSF Waveform mains cable – 250m
	41884	3 core 185mm ² LSF Waveform mains cable – 250m
	41885	3 core 300mm ² LSF Waveform mains cable – 250m
	41886	4 core 95mm ² LSF Waveform mains cable – 250m
	41887	4 core 185mm ² LSF Waveform mains cable – 250m
	41888	4 core 300mm ² LSF waveform mains cable – 250m

APPENDIX A

SUPERSEDED DOCUMENTATION

This document supersedes EE SPEC: 74/2 dated March 2015 which has now been withdrawn.

APPENDIX B

RECORD OF COMMENT DURING CONSULTATION

[EE SPEC: 74/3 - Comments](#)

APPENDIX C

KEY WORDS

None.