

Company Directive

**ENGINEERING SPECIFICATION
EE SPEC: 122**

**WPD Assessed Switchgear and Associated Plant
for Use on the Distribution Network**

Author: Anthony Smith

Implementation Date: January 2019

Approved by



Policy Manager

Date:

2 January 2019

All references to Western Power Distribution or WPD must be read as National Grid Electricity Distribution or NGED

NOTE: The current version of this document is stored in the NGED Corporate Information Database. Any other copy in electronic or printed format may be out of date. Copyright © 2022 National Grid Electricity Distribution

IMPLEMENTATION PLAN

Introduction

This document provides a guide for the selection of switchgear and associated plant items for Western Power Distribution (WPD) Engineering Design and Network Services, Independent Connections Providers and other external provider contracted to WPD.

Main Changes

This is a new EESPEC.

Impact of Changes

This document replaces any and all previous listings of switchgear approved or assessed for use in Western Power Distribution including those that have been issued by Central Networks, East Midlands Electricity and Midlands Electricity (and any successor companies).

Implementation Actions

None

Implementation Timetable

This revised document shall be implemented immediately.

REVISION HISTORY

Document Revision & Review Table		
Date	Comments	Author
January 2019	<ul style="list-style-type: none">New document	Anthony Smith

1.0 PURPOSE

This document provides a guide for the selection of switchgear and associated plant items for Western Power Distribution (WPD) Engineering Design and Network Services, Independent Connections Providers and other external provider contracted to WPD.

2.0 SCOPE

The switchgear and associated plant list in Schedule 1 of this document has been prepared by WPD and covers the provision of indoor and outdoor, three phase switchgear, at 12 kV, 36kV, 72.5 kV and 145 kV for continuous service at 50 Hertz, for use on the WPD 6.6kV, 11kV, 33kV, 66kV and 132kV distribution networks.

It supersedes all previous approved/assessed switchgear lists that have been issued by Western Power Distribution including those issued by Central Networks, East Midlands Electricity and Midlands Electricity (and any successor company).

Switchgear and associated plant included in this list shall comply with the relevant International and British Standards (BS) and Energy Networks Association Technical Specifications (ENATS) listed.

The list only includes the switchgear currently in production, available in the market and assessed by WPD.

3.0 REQUIREMENTS

The switchgear shall generally, except where varied by any related WPD technical specifications (Engineering Equipment Specification – EE SPEC) comply with the appropriate requirements of all relevant sections of the Energy Networks Association Technical Specification 41-36 and 41-37 (ENATS 41-36 & 41-37); IEC 60694 and IEC 62271.

It is WPD Policy that all new switchgear shall not utilise oil as an insulating or arc interrupting medium.

Switchgear and associated plant shall have been assessed by the ENA Switchgear Assessment Panel and hold a current Notice of Conformity. It shall also have been assessed by the WPD Engineering Policy Team and determined as suitable for use on the WPD network.

4.0 CATEGORIES FOR WPD ASSESSED SWITCHGEAR AND ASSOCIATED PLANT

All items of WPD assessed switchgear and associated plant in this EE SPEC have been assigned particular assessment categories. The categories are defined below:

Category F Category F equipment has been Assessed by the WPD Engineering Policy Team and is available for purchase within WPD on a Framework Contract.

Category A Category A equipment has been Assessed by the WPD Engineering Policy Team and is available for purchase when Category F equipment is not suitable for use by virtue of ratings, need for equipment make/type diversity, for extension units to match existing units, or other significant factor.

Category S Category S equipment has been Assessed for use by the WPD Engineering Policy Team, but only for a specific contract or site.

Prior approval of the WPD Policy Team (Plant Engineer) will be required before equipment in this category can be considered for purchase, installation and use.

Prior to any Equipment being installed on the WPD network it shall have obtained an appropriate WPD Engineering Policy Team Assessment, which shall be either category “F”, “A” or “S”.

Switchgear and plant not on the WPD Assessed Switchgear and Associated Plant list may be considered for use on the WPD network subject to it having a valid ENA Notice of Conformity, and a robust WPD business justification for the WPD Policy Team completing the assessment work to allocate a “F”, “A” or “S” Assessment Category. Any request for assessment should be made to the WPD Engineering Policy Manager.

SCHEDULE

List of WPD Assessed Switchgear And Associated Plant

1.0	145KV OUTDOOR (AIS)	7
1.1	Circuit Breaker	7
1.2	Disconnectors and Earthing Switches	7
1.3	Instrument Transformers	8
2.0	145KV INDOOR (GIS)	9
2.1	Circuit Breaker	9
3.0	72.5KV OUTDOOR (AIS)	10
3.1	Circuit Breaker	10
3.2	Disconnectors and Earthing Switches	10
3.3	Fault Throwing Switch	11
3.4	Instrument Transformers	11
4.0	72.5KV INDOOR (GIS)	12
4.1	Circuit Breaker	12
5.0	36KV OUTDOOR	13
5.1	Circuit Breaker	13
5.2	Disconnectors	13
5.3	Fault Throwing Switch	14
5.4	Instrument Transformers	14
5.5	Circuit Breaker (Overhead Line - Pole Mounted)	14
5.6	Switch Disconnector / Sectionaliser (Overhead Line - Pole Mounted)	14
6.0	36KV INDOOR	15
6.1	Circuit Breaker	15
7.0	12KV	16
7.1	Circuit Breaker (Indoor)	16
7.3	Circuit Breaker (Overhead Line - Pole Mounted)	18
7.4	Switch Disconnector / Sectionaliser (Overhead Line - Pole Mounted)	18
7.5	Secondary Ring Main Units and Extensible	19
7.6	Disconnectors and Miscellaneous Fusegear (Overhead Line - Pole Mounted)	20
8.0	400/230V LOW VOLTAGE FUSE CABINETS	21
9.0	TRANSFORMERS	21

SCHEDULE - LIST OF WPD ASSESSED SWITCHGEAR AND ASSOCIATED PLANT**1.0 145KV OUTDOOR (AIS)****1.1 Circuit Breaker**

	Manufacturer	Designation	Equipment Description	I (normal) (A)	3second Short Time Withstand Current (kA)	WPD Assessment Category	ENA Assessment		
							Type	No	Issue
1	UK Grid Solutions (GE Alstom) [Charleroi, USA]	DT1-145 F1 FK3-1	145kV dead tank outdoor SF6 circuit breaker [SCBC - 45ms @ 40.0kA; 135ms @ 31.5kA]	2500	40kA	F	NOC	1081	3
2	UK Grid Solutions (GE Alstom)	GL312	145kV Live tank outdoor SF6 circuit breaker	3150	31.5/40kA to EATS 41-10	A	NOC	1004	3.1
3	Siemens	3AP1-DT – 1S	145kV dead tank outdoor SF6 circuit breaker [* - 2500A with composite insulators] [SCBC - 45ms @ 40.0kA; 135ms @ 31.5kA]	3150*	31.5kA/40kA to EATS 41-37	F	NOC	1131	1
4	Siemens	3AP1-FG	145kV live tank outdoor SF6 circuit breaker	3150	40kA	F	NOC	1002	2.1

1.2 Disconnectors and Earthing Switches

	Manufacturer	Designation	Equipment Description	I (normal) (A)	3second Short Time Withstand Current (kA)	WPD Assessment Category	ENA Assessment		
							Type	No	Issue
1	UK Grid Solutions (GE Alstom)	S3C	2000A single break 145kV 40kA Disconnector TypeS S3C; S3C/T & S3C/B/T	1250 2000	31.5kA	S	NOC	1068 1069	3 3
2	UK Grid Solutions (GE Alstom)	STA	145kV Type STA free standing earthing switch and Disconnector Mounted earthing switch type (/T)	-	40kA	S	NOC	1071	3

1.3 Instrument Transformers

	Manufacturer	Designation	Equipment Description	I (normal) (A)	3second Short Time Withstand Current (kA)	WPD Assessment Category	ENA Assessment		
							Type	No	Issue
1	ABB	IMB-145	Current Transformer (hairpin type)	1250 2000	63kA / 40kA 1s/3s	A	NOC	1039	2.1
2	ABB	CPB145	Capacitor Voltage Transformer Rated voltage 132/√3;- secondary 110/√3	-	-	A	NOC	1079	1.2
3	Arteche	CA-145	Current Transformer (bar primary type)	2000	80kA / 40kA 1s/3s	A	NOC	1060	1.2
4	Arteche	KA-145	Combined metering transformer	2000	80kA / 40kA 1s/3s	A	NOC	1061	2.2
5	Pfiffner	EOF 145	Inductive voltage transformer	-	-	S	NOC	1132	1
6	Pfiffner	ECF 145	Capacitive voltage transformer	-	-	S	NOC	1128	1
7	Pfiffner	JOF 145	Current transformer	2000		S	NOC	1127	1
8	Pfiffner	EJOF 145	Combined metering transformer	-	-	S	NOC	1129	1
9	Siemens (Trench)	IVOKT 145	HAM metering CTVT unit [Only units manufactured in France]	-	-	S	-	-	-
10	Siemens (Trench)	VEOT 145	Wound voltage transformer [Only units manufactured in France]	-	-	S		-	-

2.0 145KV INDOOR (GIS)

2.1 Circuit Breaker

	Manufacturer	Designation	Equipment Description	I (normal) (A)	3second Short Time Withstand Current (kA)	WPD Assessment Category	ENA Assessment		
							Type	No	Issue
-	-	-	-	-	-	-	-	-	-

NOTE: No gas-insulated metal-enclosed 145kV switchgear is assessed for new application within WPD. [ST:SD1C]

3.0 72.5KV OUTDOOR (AIS)

3.1 Circuit Breaker

	Manufacturer	Designation	Equipment Description	I (normal) (A)	3second Short Time Withstand Current (kA)	WPD Assessment Category	ENA Assessment		
							Type	No	Issue
1	UK Grid Solutions (GE Alstom) [Charleroi, USA]	DT1-72.5 F1 FK3-1	72.5kV outdoor dead tank SF6 circuit breaker	2500	40kA	F	NOC	1105	1.1
2	Siemens	3AP1-DT 72.5	72.5kV outdoor dead tank SF6 circuit breaker	3150	25/31.5kA	A	NOC	1030	2

3.2 Disconnectors and Earthing Switches

	Manufacturer	Designation	Equipment Description	I (normal) (A)	3second Short Time Withstand Current (kA)	WPD Assessment Category	ENA Assessment		
							Type	No	Issue
1	UK Grid Solutions (GE Alstom)	S3C	Disconnecter – rotating post double break	2000	40kA	A	NOC	1117	1
2	UK Grid Solutions (GE Alstom)	STW	Free standing earthing switch and Disconnecter mounted earthing switch (/T/H)	-	40kA	A	NOC	1115	1
3	UK Grid Solutions (GE Alstom)	STW	Disconnecter mounted line earthing switch and Free standing line earthing switch (/T/H)	-	40kA	A	NOC	1116	1
4	MLE (Morris Line Engineering)	RDB	Disconnecter – rotating post double break	up to 2000	25 or 31.5kA/3s	A	-	-	-
5	Power Isolators (Lucy)	Rapier	Disconnecter – rotating post double break			A	-	-	-

3.3 Fault Throwing Switch

	Manufacturer	Designation	Equipment Description	I (normal) (A)	3second Short Time Withstand Current (kA)	WPD Assessment Category	ENA Assessment		
							Type	No	Issue
1	Morris Line Equipment (MLE)	FTS	Fault Throwing Switch [Not permitted for new installation]	-	40kA/1s	S	-	-	-

3.4 Instrument Transformers

	Manufacturer	Designation	Equipment Description	I (normal) (A)	3second Short Time Withstand Current (kA)	WPD Assessment Category	ENA Assessment		
							Type	No	Issue
1	ABB	IMB-72	Current Transformer (hairpin type)	1600 2000	63kA / 40kA 1s/3s	A	NOC	1038	2
2	ABB	CPB72	Capacitor Voltage Transformer Rated voltage 69/V3;- secondary 110/V3	-	-	A	NOC	1079	1
3	Arteche	DDB-72	Capacitor voltage transformer	-	-	S	-	-	-
4	Arteche	UTB-72	Wound voltage transformer	-	-	S	-	-	-
5	Pfiffner	EOF 72	Inductive voltage transformer	-	-	S	NOC	1135	1
6	Pfiffner	ECF 72	Capacitive voltage transformer	-	-	S	NOC	1136	1
7	Pfiffner	JOF 72	Current transformer	<4000	<63kA 1 sec	S	NOC	1133	1
8	Pfiffner	EJOF 72	Combined metering transformer	-	-	S	NOC	1134	1
9	Siemens (Trench)	IVOKT 72.5	HAM metering CTVT unit [Only units manufactured in France]	2000	-	S	-	-	-
10	Siemens (Trench)	VEOT 72.5	Wound voltage transformer [Only units manufactured in France]	-	-	S	-	-	-

4.0 72.5KV INDOOR (GIS)

4.1 Circuit Breaker

	Manufacturer	Designation	Equipment Description	I (normal) (A)	3second Short Time Withstand Current (kA)	WPD Assessment Category	ENA Assessment		
							Type	No	Issue
-	-	-	-	-	-	-	-	-	-

NOTE: No gas-insulated metal-enclosed 72.5kV switchgear is assessed for new application within WPD. [ST:SD1C]

5.0 36KV OUTDOOR

5.1 Circuit Breaker

	Manufacturer	Designation	Equipment Description	I (normal) (A)	3second Short Time Withstand Current (kA)	WPD Assessment Category	ENA Assessment		
							Type	No	Issue
1	Hawker Siddeley Switchgear Ltd.	Horizon	Outdoor dead tank - vacuum in SF ₆	1250 2000	25kA	F	NOC	1034	2.1
2	Schneider	VOX	Outdoor dead tank - vacuum in SF ₆	1250 2000	25kA / 31.5kA / 40kA	S	NOC	1029	3.1

5.2 Disconnectors

	Manufacturer	Designation	Equipment Description	I (normal) (A)	3second Short Time Withstand Current (kA)	WPD Assessment Category	ENA Assessment		
							Type	No	Issue
1	MLE (Morris Line Equipment)	MLS	36kV Outdoor pole mounted Air Break Switch Disconnecter Manual independent spring assisted high level rod operated mechanism. Fitted with 400 amp interrupter heads	630	25kA	F	NOC	1012	2
2	MLE (Morris Line Equipment)	ML	36kV overhead conductor connected three phase Air Break Switch Disconnecter [* - 400A interrupter heads]	630*	25kA	F	NOC	1012	2
3	MLE (Morris Line Equipment)	RDB	36kV Disconnecter – rotating post double break	up to 2000	25 or 31.5kA/3s	A	-	-	-
4	MLE (Morris Line Equipment)	Type R	36kV Outdoor Air Break Switch Disconnecter Fitted with interrupter heads (CAT 0)	800 1250	25kA / 3s	A	-	-	-
5	Power Isolators (Lucy)	Rapier DSB	36kV Double side break Disconnecter Fitted with interrupter heads (CAT 0)	800	25kA / 3s	A	-	-	-

5.3 Fault Throwing Switch

	Manufacturer	Designation	Equipment Description	I (normal) (A)	3second Short Time Withstand Current (kA)	WPD Assessment Category	ENA Assessment		
							Type	No	Issue
1	Morris Line Equipment (MLE)	FTS	36kV Fault Throwing Switch [Not permitted for new installation] [Note: A covered FTS is required where all other plant on site is enclosed conductor.]	-	40kA/1s	A	-	-	-

5.4 Instrument Transformers

	Manufacturer	Designation	Equipment Description	I (normal) (A)	3second Short Time Withstand Current (kA)	WPD Assessment Category	ENA Assessment		
							Type	No	Issue
1	Transmag	“Trident”	Wound VT – oil insulated	-	-	F	-	-	-

5.5 Circuit Breaker (Overhead Line - Pole Mounted)

	Manufacturer	Designation	Equipment Description	I (normal) (A)	3second Short Time Withstand Current (kA)	WPD Assessment Category	ENA Assessment		
							Type	No	Issue
1	Nulec (Schneider)	N38 N Series	36kV Outdoor pole mounted circuit breaker (vacuum interrupter)	800	12kA	F	-	-	-

5.6 Switch Disconnecter / Sectionaliser (Overhead Line - Pole Mounted)

	Manufacturer	Designation	Equipment Description	I (normal) (A)	3second Short Time Withstand Current (kA)	WPD Assessment Category	ENA Assessment		
							Type	No	Issue
1	Nulec (Schneider)	RL38 R Series	36kV Outdoor pole mounted SF6 switch disconnecter	630	16kA	F	NOC	1102	1.1

6.0 36KV INDOOR

6.1 Circuit Breaker

	Manufacturer	Designation	Equipment Description	I (normal) (A)	3second Short Time Withstand Current (kA)	WPD Assessment Category	ENA Assessment		
							Type	No	Issue
1	Schneider	GHA 36-25-12 GHA 36-25-20	36kV indoor circuit breaker SF6 insulated vacuum interrupters [45ms & 120ms DC Time Constant]	1250 2000	25kA	F	NOC	1075	2.1
2	Siemens	NX+ 36 V1.0	36kV indoor circuit breaker SF6 insulated vacuum interrupters (single busbar) [120 ms DC Time Constant]	1250 2000	31.5kA	F	NOC	1033	4
3	Schneider	WSA 36	36kV indoor circuit breaker SF6 insulated vacuum interrupters (single busbar) [45ms & 120ms DC Time Constant]	2000 2500	31.5kA	A	NOC	1049	1
4	Ormazabal	CPG.0	36kV indoor circuit breaker SF6 insulated vacuum interrupters [45ms DC Time Constant] Variants: feeder circuit breaker (CPG.0-V); non- auto feeder circuit-breaker (CPG.0-L); bus- section circuit breaker (CPG.0-C)	1250	25kA	S	NOC	1074	3

[Note: Item 4 – ICP supplied only]

7.0 12KV

7.1 Circuit Breaker (Indoor)

	Manufacturer	Designation	Equipment Description	I (normal) (A)	3second Short Time Withstand Current (kA)	WPD Assessment Category	ENA Assessment		
							Type	No	Issue
1	Hawker Siddeley Switchgear	Quantum	Circuit Breaker (Fixed Pattern) Magnetic actuator operated vacuum circuit breaker with integral three position disconnecter / earthing switch. Air insulated busbars.	630 1250 2000	25kA	F	NOC	1140	1
2	Hawker Siddeley Switchgear	Eclipse	Circuit Breaker (Fixed Pattern) Magnetic actuator operated vacuum circuit breaker with integral three position disconnecter / earthing switch. Air insulated busbars. [Note: Only to extend existing installations]	630 1250 2000	25kA	A	NOC	1024	4
3	Schneider	Genie Evo	Circuit Breaker (Fixed Pattern) 630A feeder; 1250A incomer with fixed VT (removable primary fuses) & top and bottom entry cable compartment; 630A & 1250A Bus-section & 'riser'	630 1250 2000	25kA 45ms D.C. component –27%	F	NOC	1032	7

7.2 Retrofit Circuit Breakers (Indoor)

	Manufacturer	Designation	Equipment Description	I (normal) (A)	3second Short Time Withstand Current (kA)	WPD Assessment Category	ENA Assessment		
							Type	No	Issue
1	Hawker Siddeley Switchgear	SWR 12/25	12kV Indoor moving portion. For replacement of OCB in SWS type C4X/D4X legacy housing/ back part with <ul style="list-style-type: none"> busbars arranged vertically ('High' type) busbars arranged horizontally ('Low' type) [Rated normal current and rated short-circuit breaking current in use will be restricted by the fixed portion]	400/630 800 1250	25kA; 45ms time constant [Earthing adaptor equivalent to 13.1kA break /33kA make]	F	NOC	1112	1
2	Hawker Siddeley Switchgear	BSR 12/25	12kV Indoor moving portion For replacement of OCB and VCB in Brush type VSI, VTD & VMV (D) legacy housing/ back part. [Rated normal current and rated short-circuit breaking current in use will be restricted by the fixed portion]	400/630 800 1250	25kA; 45ms time constant	F	NOC	1137	2
3	Siemens	LMT-SION	12kV Indoor moving portion for use with Reyrolle LMT fixed portion. Refer to ENA NoC for specific application. [Rated normal current and rated short-circuit breaking current in use will be restricted by the fixed portion]	630 1250 2000	20kA; (630A) 25kA; (1250A & 2000A) 45ms time constant	S	NOC	1103	3

7.3 Circuit Breaker (Overhead Line - Pole Mounted)

	Manufacturer	Designation	Equipment Description	I (normal) (A)	3second Short Time Withstand Current (kA)	WPD Assessment Category	ENA Assessment		
							Type	No	Issue
1	Nulec (Schneider)	U27 U Series	12kV Outdoor pole mounted circuit breaker (vacuum interrupter)	630	12.5kA	F	NOC	1100	1

7.4 Switch Disconnecter / Sectionalizer (Overhead Line - Pole Mounted)

	Manufacturer	Designation	Equipment Description	I (normal) (A)	3second Short Time Withstand Current (kA)	WPD Assessment Category	ENA Assessment		
							Type	No	Issue
1	Nulec (Schneider)	RL27 R Series	12kV Outdoor pole mounted SF6 switch disconnecter	630	16kA	F	NOC	1102	1

7.5 Secondary Ring Main Units and Extensible

	Manufacturer	Designation	Equipment Description	I (normal) (A)	3second Short Time Withstand Current (kA)	WPD Assessment Category	ENA Assessment		
							Type	No	Issue
1	Lucy	SABRE VRN2A	12kV Outdoor RMU [630A ring switches / 250A circuit breaker	250 630	20kA 3 sec. 95kV	F	NOC	1041	2
2	Schneider	RN2d	12kV Outdoor RMU 200A SF6 CB (95 kV BIL)	630	21kA	F	NOC	1130	2
3	Schneider	RN6d	12kV Outdoor RMU 630A SF6 CB (95 kV BIL)	630	21kA	F	NOC	1130	2
4	Schneider	RN2c	12kV Outdoor RMU 200A SF6 CB (95 kV BIL) [To be replaced by RN2d during 2019]	630	21kA	A	NOC	1007	2.1
5	Schneider	RN6c	12kV Outdoor RMU 630A SF6 CB (95 kV BIL) [To be replaced by RN6d during 2019]	630	21kA	A	NOC	1007	2.1
6	Schneider	MU2	12kV Air Insulated Metering Unit (75kV BIL)	200 630	16kA	F	-	-	-
7	Schneider	CE2	12kV Outdoor extensible SF6 switch disconnecter (95kV BIL)	200	20kA	F	NOC	1085	1
8	Schneider	CE6	12kV Outdoor extensible SF6 switch disconnecter (95kV BIL)	630	20kA	F	NOC	1085	1
9	Schneider	CE6-B5	12kV Outdoor extensible SF6 bus-section circuit breaker	630	20kA	F	NOC	1085	1
10	Schneider	CN2	12kV Outdoor non-extensible SF6 circuit breaker (75kV BIL)	200	20kA	F	NOC	1085	1
11	Schneider	SE6	12kV Outdoor extensible SF6 switch disconnecter (95kV BIL)	630	20kA	F	NOC	1086	1.1
12	Schneider	SE6-B1	12kV Outdoor extensible SF6 bus-section switch disconnecter	630	20kA	F	NOC	1086	1.1
13	Schneider	SE6-E1	12kV Outdoor extensible SF6 busbar earth switch (95kV BIL)	630	20kA	F	NOC	1086	1.1

[Note: Units shall be WPD variants and ordered using relevant WPD E5 and Manufacturer codes.]

[Note: Items 3 and 4 – ICP supplied only]

7.6 Disconnectors and Miscellaneous Fusegear (Overhead Line - Pole Mounted)

	Manufacturer	Designation	Equipment Description	I (normal) (A)	3second Short Time Withstand Current (kA)	WPD Assessment Category	ENA Assessment		
							Type	No	Issue
1	Morris Line Equipment (MLE)	-	12kV Outdoor pole mounted Air Break Switch Disconnecter Rated short-circuit making current 25kA pk. Manual independent spring assisted high level rod operated mechanism. Fitted with 400 amp interrupter heads (CAT 0)	630A load 400A break	10kA	F	-	-	-
2	Allied Insulators	-	12kV Outdoor pole mounted Air Break Switch Disconnecter Rated short-circuit making current 25kA pk. Manual independent spring assisted high level rod operated mechanism. Fitted with 400 amp interrupter heads (CAT 0)	630A load 400A break	10kA	F	-	-	-
3	Morris Line Equipment (MLE)	-	12kV Outdoor pole mounted Air Break Switch Disconnecter Rated short-circuit making current 25kA pk. Dependent Manual high level rod operated mechanism with arcing horns. (CAT 2)	630A load 20A break	3kA	F	-	-	-
4	Allied Insulators	-	12kV Outdoor pole mounted Air Break Switch Disconnecter Rated short-circuit making current 25kA pk. Dependent Manual high level rod operated mechanism with arcing horn. (CAT 2)	630A load 20A break	3kA	F	-	-	-
5	Cooper Power Systems	Type L Cut-out L9COP1A	27kV Pole mounted Dropout Expulsion Fuse to NEMA standard. Including: 100 amp fuse holder LDCA00A 300 amp link LDC300A.	Up to 300	10kA	A	-	-	-
6	Cooper Bussmann	27ASL50CR5-2	27kV Automatic Sectionalising Link for use in NEMA standard 27kV cut-out	Up to 50	10kA	A	-	-	-

8.0 400/230V LOW VOLTAGE FUSE CABINETS

	Manufacturer	Designation	Equipment Description	I (normal) (A)	3second Short Time Withstand Current (kA)	WPD Assessment Category	ENA Assessment		
							Type	No	Issue
1	Lucy	Acculock	Transformer mounted LV cabinet	1600		A	NOC	1083 1087	1.1 1.1
2	Schneider	Shielded LV Cabinet	Transformer mounted LV cabinet	1600		F	NOC	1054 1056 1058	3.1 3.1 3.1

9.0 TRANSFORMERS

WPD Assessed Manufacturers of power transformers are:

Manufacturer	Voltage										
	132/66	132/33	132/11	132/11/11	66/33	66/11	66/11/11	33/11	11/0.400/0.230 (GM)	11/0.400/0.230 (PM)	11/0.400/0.230 (Padmount)
ABB	X	X	X	X							
Brush								X			
CG											
Cooper											X
Pauwels											
Schneider											
Siemens	X	X	X	X							
SGB	X	X	X	X							
Tironi	X	X	X	X							

APPENDIX A

SUPERSEDED DOCUMENTATION

This document replaces any and all previous listings of switchgear assessed or approved for use in Western Power Distribution including those that have been issued by Central Networks, East Midlands Electricity and Midlands Electricity (and any successor companies).

APPENDIX B

ASSOCIATED DOCUMENTATION

Current versions of:-

EE SPEC 2	“12kV Cable Connected Outdoor Switchgear – Non Oil”
EE SPEC 7	“Switchgear for use on 66kV and 132kV Distribution Systems”
EE SPEC 10	“12kV and 36kV Outdoor Overhead Conductor Connected Switchgear and Voltage Transformers”
EE SPEC 13	“12kV and 36kV Pole Mounted Enclosed Switchgear – Non Oil Type”
EE SPEC 16	“LV Distribution Fuseboards”
EE SPEC 182	“36kV Indoor Primary Circuit Breakers”
EE SPEC 185	“12kV Indoor Circuit Breakers”
ST:SD1C	“Selection and Application of WPD Assessed Switchgear for Use on the Distribution Network”

APPENDIX C

POLICY IMPLEMENTATION

This specification is implemented on issue. There is no retrospective action required as a result of the issue of this document.

APPENDIX D

POLICY IMPACT

This document is relevant to all staff involved with the specification, purchase, design, and installation of new switchgear and associated plant.

APPENDIX E

KEY WORDS

Assessed; Assessed Switchgear; Circuit Breaker; Disconnecter; Instrument Transformer; VT; CT