

Alfreton

 DNOA Decision
Remove

Scheme description

Meadow Lane (Alfreton) has two 33/11 kV transformers. For the loss of a single 33/11 kV transformer the site is supplied from the remaining transformer. Internal analysis has identified there is little remaining headroom for further demand.



Constraint Season
None



Flexibility Product
Secure

Justification for decision


Constraint no longer an issue until at least 2027 under every scenario.

Constraint management timeline

- 2023 H1 **None**
- 2022 H2 Procurement
- 2022 H1 Procurement
- 2021 H2 Procurement
- 2021 H1 Procurement
- 2020 H2 Procurement
- 2020 H1 Procurement

Estimated flex utilisation required per year (MWh):

	2023	2024	2025	2026	2027
BV					
CT					
LTW					
ST					
SP					



For more information visit: nationalgrid.co.uk/network-flexibility-map-application