

Weedon

 DNOA Decision
Remove

Scheme description

Weedon primary is a single transformer site with a firm capacity limited by the 11 kV backfeed capability. The 11 kV backfeed capability is limited by the firm capacity of Bugbrooke primary (another single transformer site). The proposed reinforcement is to install a new 11 kV circuit between Bugbrooke and Weedon and replace the existing transformer at Bugbrooke.



Constraint Season
None



Flexibility Product
Secure

Justification for decision


Constraint no longer an issue until at least 2027 under every scenario.

Constraint management timeline

2023 H1 **None**
 2022 H2 Maintain Active
 2022 H1 Maintain Active
 2021 H2 Procurement
 2021 H1 Procurement
 2020 H2 Procurement
 2020 H1 Procurement
 2019 Signposting
 2018 Signposting

Estimated flex utilisation required per year (MWh):

	2023	2024	2025	2026	2027
BV					
CT					
LTW					
ST					
SP					



For more information visit: nationalgrid.co.uk/network-flexibility-map-application