

Haverfordwest – Brawdy

Scheme description

An outage on the circuit from Haverfordwest to Fishguard causes thermal and voltage constraints. The reinforcement solution is to build a new 33 kV circuit from Haverfordwest to Brawdy.

.....

Justification for decision

Studies indicate both thermal and severe voltage restrictions with varying sensitivity factors making flexibility unfeasible.

.....

Reinforcement Information

Completion Year 2027
Current Status Preliminary



DNOA Decision
Reinforce

