

Woodcote to Chard

Scheme description

The proposed reinforcement was to reinforce the Woodcote – Chard 33 kV circuits to mitigate against an N-1 thermal constraint.

.....

Justification for decision

Further network studies indicated no requirement for reinforcement in the foreseeable future.

.....

Reinforcement Information

Completion Year -

Current Status -

 DNOA Decision
Remove

