

# Lincoln – Anderson Lane



## Constraint description

The 33 kV circuit to Anderson Lane T1 was constrained for N-1 outages on the 33 kV infeed to T2.

## Reinforcement description

The reinforcement proposal was to uprate the 33 kV circuit from Lincoln BSP to Anderson Lane primary.



Constraint Season  
Winter/Summer



Flexibility Product  
Secure



Outage Type  
N-1

## Justification for decision

Reinforcement works have been completed, resolving this constraint.

## Constraint management timeline

2024 H1 None  
2023 H2 Procurement  
2023 H1 Procurement  
2022 H2 Procurement  
2022 H1 Procurement  
2021 H2 Procurement  
2021 H1 Procurement  
2020 H2 Procurement

Time to Reinforce: N/A

Constraint Type: Thermal

## Estimated flexibility price (£) and volumes (MWh) per year under Best View:

	2024	2025	2026	2027	2028	2029
Availability	-	-	-	-	-	-
Utilisation	-	-	-	-	-	-



For more information visit: [nationalgrid.co.uk/network-flexibility-map-application](https://nationalgrid.co.uk/network-flexibility-map-application)