

# Wise Street

 DNOA Decision  
**Flexibility**

## Constraint description

Wise Street is a 33/11 kV two transformer site fed out of Warwick Bulk Supply Point (BSP). Its firm capacity is limited by its 33/11 kV transformers. Demand projections indicate overloads could occur for the loss of either transformer in the future.

## Reinforcement description

The reinforcement proposal is to uprate both transformers and the 33 kV infeeds from Warwick BSP.



Constraint Season  
Winter/Summer



Flexibility Product  
Secure



Outage Type  
N-1

## Justification for decision

Flexibility procurement is required to ensure the needs of the network are met.

## Constraint management timeline

2024 H1 Procurement

**Time to Reinforce:** 3 years

**Constraint Type:** Thermal

## Estimated flexibility price (£) and volumes (MWh) per year under Best View:

	2024	2025	2026	2027	2028	2029
Availability	-	-	£1,252 / 0.3 MWh	£1,252 / 2 MWh	£1,252 / 12 MWh	£955 / 40 MWh
Utilisation	-	-	£1,753 / 0.3 MWh	£1,753 / 2 MWh	£1,753 / 12 MWh	£1,337 / 40 MWh



For more information visit: [nationalgrid.co.uk/network-flexibility-map-application](https://nationalgrid.co.uk/network-flexibility-map-application)