

Chewton Mendip

Constraint description

Chewton Mendip primary is a single 33/11 kV transformer site with firm capacity limited by the transformer itself which can result in constraints under intact conditions.

Reinforcement description

Upgrading the primary transformer.



Constraint Season
Winter/Summer



Flexibility Product
Secure



Outage Type
Intact



DNOA Decision

Remove

Justification for decision

No constraint has been identified.

Constraint management timeline

2024 H1 **None**

2023 H2 Maintain Active

2023 H1 Maintain Active

2022 H2 Procurement

Time to Reinforce: N/A

Constraint Type: Thermal

Estimated flexibility price (£) and volumes (MWh) per year under Best View:

	2024	2025	2026	2027	2028	2029
Availability	-	-	-	-	-	-
Utilisation	-	-	-	-	-	-



For more information visit: nationalgrid.co.uk/network-flexibility-map-application