

# Honiton Heathfield and Offwell Ring



DNOA Decision

**Signposting**

## Constraint description

An N-1 condition for a fault on the Ottery St Mary main 2 busbar results in an overload on the Ottery St Mary to Honiton circuit.

## Reinforcement description

Upgrading the limiting section of circuit.



Constraint Season  
Winter/Summer



Flexibility Product  
Secure



Outage Type  
N-1

## Justification for decision

No flexibility requirement under Best View until 2031.

## Constraint management timeline

2024 H1 **Signposting**

2023 H2 Signposting

2023 H1 Signposting

**Time to Reinforce:** 2 years

**Constraint Type:** Thermal

## Estimated flex utilisation required per year (MWh):

2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034
-	-	-	-	-	-	-	1 MWh	2 MWh	18 MWh	161 MWh



For more information visit: [nationalgrid.co.uk/network-flexibility-map-application](https://nationalgrid.co.uk/network-flexibility-map-application)