

# Offwell

### Constraint description

Offwell primary is a two transformer primary. In an N-1 outage for the loss of one of the transformers, the remaining transformer will be overloaded in the future.

### Reinforcement description

Upgrading both primary transformers.



Constraint Season  
Winter



Flexibility Product  
Secure



Outage Type  
N-1



DNOA Decision  
**Signposting**

### Justification for decision

No flexibility requirement under Best View until 2035.

### Constraint management timeline

2024 H1 **Signposting**

**Time to Reinforce:** 3 years

**Constraint Type:** Thermal

### Estimated flex utilisation required per year (MWh):

2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034
-	-	-	-	-	-	-	-	-	-	-



For more information visit: [nationalgrid.co.uk/network-flexibility-map-application](https://nationalgrid.co.uk/network-flexibility-map-application)