## **Probus**

## **Constraint description**

Probus primary is a single 33/11 kV transformer site with firm capacity reliant on 11 kV interconnection. The capacity is expected to be exceeded for an outage of the transformer.

## **Reinforcement description**

Installing a second primary transformer.





Constraint Season Winter/Summer Flexibility Product



Outage Type **N-1** 



DNOA Decision Remove

Justification for decision No constraint has been identified.

Constraint management timeline						
<b>2024</b>	H1	None				
2023	H2	Procurement				
2023	H1	Procurement				
2022	H2	Procurement				

Time to Reinforce: N/A Constraint Type: Security of supply

## Estimated flexibility price (£) and volumes (MWh) per year under Best View:

	2024	2025	2026	2027	2028	2029
Availability	-	-	-	-	-	-
Utilisation	-	-	-	-	-	-



For more information visit: nationalgrid.co.uk/network-flexibility-map-application