

## Chesterfield GSP

### Scheme description

Demand, generation and fault level constraints at Chesterfield GSP. The optimal reinforcement scheme is being developed in conjunction with NGET and NGESO.

### Justification for decision

Generation constraints have been identified which are not suitable for mitigation with flexibility.

### Constraint Information

**Outage Type** N-1 / N-2  
**Constraint Type** Thermal

### Reinforcement Information

**Completion Year** 2030  
**Current Status** Preliminary



DNOA Decision  
**Reinforce**

## Chesterfield Main

### Scheme description

The Chesterfield – Grassmoor 33 kV circuits have limited capacity for an N-1 circuit outage. 33 kV circuit works are being carried out to resolve this constraint (as well as uprating the transformers at Grassmoor primary).

### Justification for decision

The latest flexibility analysis carried out shows no flexibility requirements before reinforcement will be completed.

### Constraint Information

**Outage Type** N-1  
**Constraint Type** Thermal

### Reinforcement Information

**Completion Year** 2027  
**Current Status** In Construction



DNOA Decision  
**Reinforce**

## Grendon – Corby 132kV

### Scheme description

Under N-2 conditions for the loss of two of the Grendon – Corby 132 kV circuits, one of the remaining circuits potentially overloads. Reinforcement is likely to involve establishing a new GSP to the north of Grendon.

### Justification for decision

There are multiple drivers for reinforcement including both demand and generation connections.

### Constraint Information

**Outage Type** N-2  
**Constraint Type** Thermal

### Reinforcement Information

**Completion Year** 2034  
**Current Status** Preliminary



DNOA Decision  
**Reinforce**



## Coalville to Mantle Lane T1

### Scheme description

For the loss of the 33 kV circuit to Mantle Lane T2, the circuit to T1 could overload. 33 kV circuit works will be required to manage this constraint.

### Justification for decision

This zone is nested within the Loughborough BSP zone, making it unsuitable for procurement.

### Constraint Information

**Outage Type** N-1  
**Constraint Type** Thermal

### Reinforcement Information

**Completion Year** 2028  
**Current Status** Preliminary



DNOA Decision  
**Reinforce**

## Coalville to Mantle Lane T2

### Scheme description

For the loss of the 33 kV circuit to Mantle Lane T1, the circuit to T2 could overload. 33 kV circuit works will be required to manage this constraint.

### Justification for decision

This zone is nested within the Loughborough BSP zone, making it unsuitable for procurement.

### Constraint Information

**Outage Type** N-1  
**Constraint Type** Thermal

### Reinforcement Information

**Completion Year** 2028  
**Current Status** Preliminary



DNOA Decision  
**Reinforce**

## Holme Carr

### Scheme description

For an arranged or fault outage on either side of Holme Carr the remaining transformer could overload. The reinforcement plan is to replace both transformers with higher rated units.

### Justification for decision

Flexibility is not suitable here as reinforcement is triggered by asset condition.

### Constraint Information

**Outage Type** N-1  
**Constraint Type** Thermal

### Reinforcement Information

**Completion Year** 2027  
**Current Status** Preliminary



DNOA Decision  
**Reinforce**



## Hopton – Cromford

### Scheme description

Load growth indicates that the Hopton – Cromford primary group will exceed its firm capacity under N-1 (loss of either transformer). The optimal reinforcement solution is to install a second transformer at each site and a new 33 kV circuit from Winster BSP.

### Justification for decision

Reinforcement is triggered by new connections, making this scheme unsuitable for flexibility.

### Constraint Information

**Outage Type** N-1  
**Constraint Type** Thermal

### Reinforcement Information

**Completion Year** 2027  
**Current Status** Preliminary



## North Wheatley

### Scheme description

The capacity of the 11 kV backfeeds at North Wheatley primary is forecast to be exceeded in the future. The reinforcement scheme is to install a second transformer and 33 kV infeed.

### Justification for decision

Reinforcement is triggered by new connections, making this scheme unsuitable for flexibility.

### Constraint Information

**Outage Type** N-1  
**Constraint Type** Security of Supply

### Reinforcement Information

**Completion Year** 2028  
**Current Status** Preliminary



## Spondon Primary

### Scheme description

Following an arranged or fault outage on one of the transformers at Spondon primary the full site demand is picked up by the other transformer. The reinforcement proposal is to add third primary transformer.

### Justification for decision

This constraint can be managed operationally in the short to medium term with a review of the seasonal transformer ratings.

### Constraint Information

**Outage Type** N-1  
**Constraint Type** Thermal

### Reinforcement Information

**Completion Year** 2028+  
**Current Status** Preliminary



## Northampton West BSP

### Scheme description

N-1 GT constraint at Northampton West BSP. The reinforcement proposal is to reinforce Northampton BSP allowing it to pick up demand from Northampton West. This reinforcement proposal also resolves the Northampton East BSP constraint.

### Justification for decision

Reinforcement triggered by new connections and tied to the overall reinforcement plan for Northampton.

### Constraint Information

**Outage Type** N-1  
**Constraint Type** Thermal

### Reinforcement Information

**Completion Year** 2028  
**Current Status** Preliminary



DNOA Decision  
**Reinforce**

## Northampton Group

### Scheme description

The Northampton group is approaching 300 MW of group load, at which point the existing circuits will not be able to meet the security of supply obligations. A fourth circuit into the group is being built to resolve this issue.

### Justification for decision

Flexibility is not feasible due to the configuration of the group and varying sensitivity factors.

### Constraint Information

**Outage Type** N-2  
**Constraint Type** Thermal

### Reinforcement Information

**Completion Year** 2028  
**Current Status** Preliminary



DNOA Decision  
**Reinforce**

## Northampton East BSP

### Scheme description

N-1 GT constraint at Northampton East BSP. The reinforcement proposal is to reinforce Northampton BSP allowing it to pick up demand from Northampton East. This reinforcement proposal also resolves the Northampton West BSP constraint.

### Justification for decision

Reinforcement triggered by new connections and tied to the overall reinforcement plan for Northampton.

### Constraint Information

**Outage Type** N-1  
**Constraint Type** Thermal

### Reinforcement Information

**Completion Year** 2028  
**Current Status** Preliminary



DNOA Decision  
**Reinforce**



## Staythorpe C to AD1C Circuit

### Scheme description

Two spans of 132 kV overhead line between Staythorpe C and tower AD1C are constrained. The proposed reinforcement solution is to uprate these two spans.

### Justification for decision

The proposed reinforcement works are below the threshold for economic viability.

### Constraint Information

**Outage Type** N-2  
**Constraint Type** Thermal

### Reinforcement Information

**Completion Year** 2024  
**Current Status** Preliminary



DNOA Decision  
**Reinforce**

## Walpole to Spalding Tee 132kV

### Scheme description

Demand and generation thermal constraints on the 132 kV circuits between Walpole GSP and Spalding BSP. Building a new GSP at Bainton will resolve this constraint.

### Justification for decision

There are multiple drivers for reinforcement including both demand and generation connections.

### Constraint Information

**Outage Type** N-1  
**Constraint Type** Thermal

### Reinforcement Information

**Completion Year** 2028  
**Current Status** Preliminary



DNOA Decision  
**Reinforce**

## Willington – Derby South – Spondon

### Scheme description

Various outage conditions can overload the circuits from Derby South Bulk Supply Point (BSP) to Spondon BSP. Reinforcement solution involves multiple projects, including reconfigurations of Willington GSP and Spondon BSP.

### Justification for decision

Flexibility is not feasible due to the complex nature of the constraint, and the fact that the proposed reinforcement has multiple drivers (including fault levels).

### Constraint Information

**Outage Type** N-1  
**Constraint Type** Thermal

### Reinforcement Information

**Completion Year** 2029  
**Current Status** Preliminary



DNOA Decision  
**Reinforce**



## Wingerworth

### Scheme description

The capacity of the 11 kV backfeeds at Wingerworth primary is forecast to be exceeded in the future. The reinforcement scheme is to install a second transformer and 33 kV infeed.

### Justification for decision

Constraint is too complex for mitigation through flexibility, and no flexibility requirements have been identified in the short term.

### Constraint Information

**Outage Type** N-1  
**Constraint Type** Security of Supply

### Reinforcement Information

**Completion Year** 2028  
**Current Status** Preliminary



DNOA Decision  
**Reinforce**

## Wise Street

### Scheme description

Following an arranged or fault outage on one of the transformers at Wise Street primary the full site demand is picked up by the other transformer. The reinforcement proposal is to update both transformers and 33 kV circuits to Wise Street.

### Justification for decision

Reinforcement is triggered by new connections, making this scheme unsuitable for flexibility.

### Constraint Information

**Outage Type** N-1  
**Constraint Type** Thermal

### Reinforcement Information

**Completion Year** 2028  
**Current Status** Preliminary



DNOA Decision  
**Reinforce**

