

# Leicester North BSP

 DNOA Decision  
**Signposting**

**Constraint description**

Leicester North BSP has two 132/33 kV Grid Transformers (GTs) which are projected to be constrained due to demand growth for an N-1 (fault or arranged outage on either GT).

**Reinforcement description**

By installing a third GT at Leicester BSP, demand can be transferred away from Leicester East and Leicester North BSPs (alleviating this constraint).



Constraint Season  
Winter and Summer



Outage Type  
N-1

**Justification for decision**

No flexibility requirement under Best View until 2034.

**Constraint management timeline**

2024 H2 Signposting

**Time to Reinforce:** 3 years

**Constraint Type:** Demand

**Estimated flexibility volumes (MWh) per year under Best View:**

2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034
-	-	-	-	-	-	-	-	-	-	2 MWh



For more information see the **Enderby 132 kV NDP report:** <https://www.nationalgrid.co.uk/dso/network-development-plan>