

Yeovil – Coker Tee

 DNOA Decision
Signposting

Constraint description

An N-1 outage on the 33 kV circuit from Yeovil Bulk Supply Point (BSP) to Montacute primary leaves Coker, East Chinnock, Martock T1 and Montacute primaries fed via a single 33 kV circuit. Demand forecasts indicate this outage will cause an overload on this circuit in the future.

Reinforcement description

Upgrading the existing circuit.



Constraint Season
Winter/Summer



Flexibility Product
Secure



Outage Type
N-1

Justification for decision

No flexibility requirement under Best View until 2030.

Constraint management timeline

2024 H1 Signposting

2023 H2 Signposting

2023 H1 Signposting

Time to Reinforce: 2 years

Constraint Type: Thermal

Estimated flex utilisation required per year (MWh):

2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034
-	-	-	-	-	-	3 MWh	34 MWh	264 MWh	1,169 MWh	3,386 MWh



For more information visit: nationalgrid.co.uk/network-flexibility-map-application